

SPECIFICATIONS:

① DOOR:
ALUMINUM 1/4" DIAMOND PLATE, MILL FINISH WITH A LIVE LOAD OF 250PSF WITH A MAX SPAN DEFLECTION OF L/150

② FRAME:
ALUMINUM, 1/4" EXTRUSION, GRAY PRIMER FINISH ON EXTERIOR SURFACES THAT COME INTO CONTACT WITH CONCRETE

③ HINGES: TYPE 316 STAINLESS STEEL

④ SLAM LATCH:
ZINC-PLATED STEEL WITH INSIDE HANDLE MECHANISM AND OUTSIDE REMOVABLE HANDLE

⑤ COUNTER-BALANCE SPRING:
ENCLOSED, TYPE 17-7 SST SPRING

⑥ HOLD-OPEN ARM: TYPE 316 STAINLESS STEEL

OPTIONAL SELF-CLOSING MECHANISM

⑦ ANCHOR: 3/8" HOLES PROVIDED, BOLTS SUPPLIED BY OTHERS

⑧ PLUG SEAL: TYPE 316 STAINLESS STEEL




CERTIFICATION: 2-HOUR FIRE RATED, WARNOCK HERSEY LABELED AND TESTED TO NFPA 288: STD METHODS OF FIRE TEST OF HORIZONTAL FIRE DOOR ASSEMBLIES. MAX TEMPERATURE RISE OF 250F.

APPLICATION NOTE: FLOOR DOOR MUST BE KEPT DRY BEFORE, DURING, AND AFTER INSTALLATION. FOR DRY, INTERIOR INSTALLATION ONLY. NOT INTENDED FOR EXTERIOR OR WET ENVIRONMENTS.

FLOOR DOOR SIZE:


PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BABCOCK-DAVIS. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BABCOCK-DAVIS IS PROHIBITED. ©2020 BABCOCK-DAVIS

PROJECT:					
ARCHITECT:					
CONTRACTOR:					
QTY:					
PART#:					
 9300 73rd Avenue North Brooklyn Park, MN 55428				TITLE: FD, 2hr Fire Rated, 250 psf, Sngl Dr, Alum, 1/4" Dmd Plt, Mill, Angle Frame, Bolt-In, SST Spring Asst, 316 SST HDW, Slam Latch w/Hdl	
	NAME	DATE	SIZE	DWG. NO.	REV
DRAWN	BES		A	Babcock FD BFDPA_X_SWL-BI ShpDr	
RELEASED	BES		WEIGHT:	SHEET 1 OF 2	




6 LAYERS GYPSUM
REQ'D TO ACHIEVE
FIRE RATING

3 LAYERS
GYPSUM



**BOLT-IN
DETAIL**



SLAM LATCH DETAIL



9300 73rd Avenue North
Brooklyn Park, MN 55428

TITLE: FD, 2hr Fire Rated, 250 psf,
Sngl Dr, Alum, 1/4" Dmd Plt,
Mill, Angle Frame, Bolt-In,
SST Spring Asst, 316 SST HDW, Slam Latch w/Hdl

	NAME	DATE	SIZE	DWG. NO.	REV
DRAWN	BES		A	Babcock FD BFDFA_X_SWL-BI ShpDr	
RELEASED	BES		WEIGHT:		